

January 2026

## DECLARATION

It is hereby declared that the copper tube **MediClim®**, manufactured by Serravalle Copper Tubes S.r.l. (SCT), is produced in accordance with the following standards:

- **EN 12735-1** – Copper and copper alloys – Seamless, round copper tubes for air conditioning and refrigeration – Part 1: Tubes for piping systems
- **EN 13348** – Copper and copper alloys – Seamless, round copper tubes for medical gases or vacuum

**MediClim®** is made of phosphorus-deoxidized copper with a minimum copper content of 99.9% (CW024A – Cu-DHP).

The inner surface quality is ensured by dedicated technological processes. All tubes are capped at both ends with plastic caps in order to preserve internal cleanliness until installation.

Due to these characteristics, **MediClim®** is suitable for the following applications:

- Air conditioning systems and refrigerant gas conveying (e.g. R32, R410A, R407C, R290)
- Transport of medical gases
- Vacuum systems
- Conveying of technical gases

The product is suitable for use in compliance with applicable regulations, including:

- European Directive **2014/68/EU** (Pressure Equipment Directive – PED)
- **EN ISO 7396-1** – Medical gas pipeline systems – Systems for compressed medical gases and vacuum



Serravalle Copper Tubes S.r.l.  
a Socio Unico  
Sede Legale  
15069 – Serravalle Scrivia (AL)  
Via Cassano, 113

Phone: + 39 0143 609 1  
PEC: ktubes@legalmail.it  
www.sctubes.com  
www.kme.com

Cap. Soc. € 3.000.000,00 iv  
Cod. Fiscale e Reg. Imprese  
di Alessandria 06600700485  
Partita IVA IT06600700485